

真岡市公共下水道事業下水汚泥等の放射性物質測定結果一覧表

令和7年5月13日現在

	真岡市水処理センター				真岡市二宮水処理センター			
測定 年度	測定日	測 定 項 目			測定日	測 定 項 目		
		脱水汚泥(単位:Bq/kg)				脱水汚泥(単位:Bq/kg)		
		Cs-134	Cs-137	合計		Cs-134	Cs-137	合計
R7	R7.5.2	ND	ND	ND	R7.5.2	ND	ND	ND
R6	R6.5.9	ND	ND	ND	R6.5.9	ND	ND	ND
	R6.8.2	ND	ND	ND	R6.8.2	ND	ND	ND
	R6.11.8	ND	ND	ND	R6.11.8	ND	ND	ND
	R7.2.7	ND	ND	ND	R7.2.7	ND	ND	ND
R5	R5.5.25	ND	ND	ND	R5.5.25	ND	ND	ND
	R5.8.4	ND	ND	ND	R5.11.10	ND	ND	ND
	R5.11.10	ND	ND	ND	*R6.1.12	ND	ND	ND
	R6.2.29	ND	ND	ND	R6.2.29	ND	ND	ND
R4	R4.5.12	ND	ND	ND	R4.5.12	ND	ND	ND
	R4.8.4	ND	ND	ND	R4.8.4	ND	ND	ND
	R4.11.11	ND	ND	ND	R4.11.11	ND	ND	ND
	R5.2.9	ND	ND	ND	R5.2.9	ND	ND	ND
R3	R3.4.8	ND	ND	ND	R3.4.8	ND	ND	ND
	R3.5.13	ND	ND	ND	R3.5.13	ND	ND	ND
	R3.6.10	ND	ND	ND	R3.6.10	ND	ND	ND
	R3.7.8	ND	ND	ND	R3.7.8	ND	ND	ND
	R3.8.12	ND	ND	ND	R3.8.12	ND	ND	ND
	R3.9.9	ND	ND	ND	R3.9.9	ND	ND	ND
	R3.10.14	ND	ND	ND	R3.10.14	ND	ND	ND
	R3.11.11	ND	ND	ND	R3.11.11	ND	ND	ND
	R3.12.9	ND	ND	ND	R3.12.9	ND	ND	ND
	R4.1.13	ND	ND	ND	R4.1.13	ND	ND	ND
	R4.2.10	ND	ND	ND	R4.2.10	ND	ND	ND
	R4.3.10	ND	ND	ND	R4.3.10	ND	ND	ND

※「ND」は測定結果が検出下限値:10Bq/kg未満であることを示している。

*R5.8.4の検査について、施設故障のため別日に実施。